

Emission Test Certificate

Thursday 30th July 2020

Supplier: The Laminex group Technology Centre (22 Trewin Street, Wendoree, VIC, 3355, Australia)

Sample Description: Laminex Woodgrain Collection

Date Tested: July 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (7 days):

| | |
|---|---|
| <p align="center">Green Building Council of Australia Green Star Design & As Built V1.3 - 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B</p> | <p align="center">Laminex Woodgrain Collection</p> |
| <p align="center">Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/item/hr</p> | <p align="center">Total Volatile Organic Compound Emission Rate: 0.018 mg/item/hr</p> |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Consultant



Tuan Duong
B.Eng. (Chemical)
Consultant

V2007093