

# Emission Test Certificate

Friday 16<sup>th</sup> April 2021

Supplier: The Laminex Group Technology Centre (22 Trewin Street, Wendouree, VIC, 3355, Australia)

Sample Description: Decorated board - 27490 Melteca F2S PBD 18mm

Date Tested: March 2021 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

**Emission Data (24 hrs):**

<p align="center"><b>Green Building Council of Australia</b> Green Star Design &amp; As Built V1.3 - 13.1.2B &amp; 13.2 Green Star Interiors V1.3 - 12.1.2B</p>	<p align="center"><b>Decorated board</b> <b>27490 Melteca F2S PBD</b></p>
<p align="center">Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/m<sup>2</sup>/hr</p>	<p align="center">Total Volatile Organic Compound Emission Rate: 0.018 mg/m<sup>2</sup>/hr</p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Travis Hale  
BSc (Biotechnology)  
Consultant



Dr. Tuan Duong  
PhD, B.Eng. (Chemical)  
Senior Consultant

**V2103057**