



NATA Accredited Laboratory

Accreditation No: 15305

Accredited for compliance with
ISO/IEC 17025 - Testing

Laminex[®]

a division of Laminex Group Pty Ltd ABN 98 004 093 092

The Laminex Group Technology Centre

Postal Address: PO BOX 720, Wendouree, Vic 3355

Address: 22 Trewin St, Wendouree, Vic 3355

Telephone: (03) 5337 3613

Fax: (03) 5337 3647

Test Report No.
1924175

Date of Issue
28/05/2019

Client:
Laminex New Zealand
1 O'Rorke Road
Penrose
Auckland
New Zealand

This test report shall not be reproduced, except in full,
without written approval from The Laminex Group Technology Centre

The material contained in this report is confidential to the entity identified as 'Client' above.



As the sample(s) have been provided by the client, the results contained in this report apply only to the sample(s) as received.

Test Report No. 1924175

Date of Issue: 28/05/2019

Laminex Sample Reference No.	24175
Client Sample Reference No.	Strandsarking
Product Description: (Supplied by client)	17mm Strandsarking
Surface Treatment	None (raw)
Receive Date:	15/04/2019
Condition:	Good.
Specification Standard	AS/NZS 1859.1:2017

Sample photographs



Test	Method	Unit	Result		Product limit		Compliance
			Mean	Std Dev	Limit Value	Standard Clause	
Formaldehyde Emission	AS/NZS 4266.1: 2017 Section 17	mg/L	0.16	0.00	Maximum 0.3 (SE0)	Clause 6.3 Table 1	PASS SE0

Formaldehyde Emission Class: Super E0

Comments

As agreed to by the client, compliance to product limits is based solely on the reported test result(s) and no uncertainty of measurement shall be taken into account.

Approved Signatory:

Laboratory Manager (J. Smolenaers)...